

# Accommodating household electrification within a growing city

Bjorn Sturmborg, Marnie Shaw, Bin Lu


School of Engineering




Australian  
National  
University



# Acknowledgement of Country





**Distribution Network**  
30-40% of bills  
50% for sunk costs

**Demand forecast** → **Infrastructure build** → **Costs locked in**



Demand growth **forecast**  $\approx$  population growth



Demand growth **forecast**  $\approx$  population growth **+ ELECTRIFICATION**



## Peak


^ Demand growth **forecast**  $\approx$  population growth **+ ELECTRIFICATION**

**+ BEHAVIOUR**




# Demand is highly variable

2022 Gungahlin zone substation



# Networks have spare capacity

2022 Gungahlin zone substation



build for this


this is underutilised

av. ~40% capacity



# Networks have spare capacity

2022 Gungahlin zone substation



*“before we **build more network**,  
we **use more network**”*  
– AER Chair, Clare Savage

build for this

this is underutilised

av. ~40% capacity



# Our research

How much electrification *could*\* fit into spare zone substation capacity?



# Our research

How much electrification *could*\* fit into spare zone substation capacity?

## Inputs & assumptions

### **ACT in 2045:**

- 100% private electric vehicles,
- 100% electric hot water,
- 42% population growth



# Our research

How much electrification *could*\* fit into spare zone substation capacity?

## Inputs & assumptions

### **ACT in 2045:**

- 100% private electric vehicles,
- 100% electric hot water,
- 42% population growth
- **Excl. space heating (inflexible) & industrial (unknown)**


# Our approach: simple & practical

**Schedule** vehicle charging & water heating at **fixed times each day**



# Our approach: simple & practical

**Schedule** vehicle charging & water heating at **fixed times each day**



## Notes

Mostly solar hours


Remainder overnight

Some EVs at peak times – at public rapid chargers




# Current demand

## 2022 Gungahlin zone substation



# Population growth + new solar

## 2045 Gungahlin zone substation



### Notes

2022 electric water heating removed


Demand scaled by population growth

1500MW new solar



# Population growth + new solar

## 2045 Gungahlin zone substation




### Notes

Trim plot at zero demand



# With vehicle charging & water heating

2045 Gungahlin zone substation



## Notes


Trim plot at zero demand

Add electric hot water & vehicles



# With vehicle charging & water heating

2045 Gungahlin zone substation



## Notes


Add electric hot water & vehicles

Min demand from -80MW to -50MW



# With vehicle charging & water heating

2045 Gungahlin zone substation



build for this


this is underutilised

av. ~50% capacity



# Peak demand events are still in winter


- Population growth exceeds current limit
- Peak demand continues to occur in winter



(Gunghalin: Low Solar, High Home EV)

# Peak demand events are still in winter


- Population growth exceeds current limit
- Peak demand continues to **occur in winter**
- Peaks continue to **occur in the evening** between 17:30 and 20:00.



(Gunghalin: Low Solar, High Home EV)

# Peak demand events are still in winter

- Population growth exceeds current limit
- **Peak demand continues to occur in winter**
- Peaks continue to **occur in the evening** between 17:30 and 20:00.
- **Solar variability** create new peaks (esp Low Solar scenario in winter)




(Gunghalin: Low Solar, High Home EV)

# Peak demand events are still in winter

- Population growth exceeds current limit
- **Peak demand continues to occur in winter**
- Peaks continue to **occur in the evening** between 17:30 and 20:00.
- **Solar variability** create new peaks (esp Low Solar scenario in winter)
- **Coincident EV charging** creates new peaks

(Gunghalin: Low Solar, High Home EV)



# Conclusion

How much electrification *could* fit into spare zone substation capacity?



# Conclusion

How much electrification *could* fit into spare zone substation capacity?

**Effectively all private vehicle charging & water heating...**



# Conclusion

How much electrification *could* fit into spare zone substation capacity?

**Effectively all private vehicle charging & water heating...**

**... because inflexible demand continues to create large peaks.**



# Conclusion

How much electrification *could* fit into spare zone substation capacity?

**Effectively all private vehicle charging & water heating...**

**... because inflexible demand continues to create large peaks.**

Caveats:

- 100% customer participation @ fixed times (causes step changes)
- **Electric A/C will extenuate peak demand beyond our modelling...**  
**... creating more headroom for flexible loads**
- Electrified loads lift min demand by 30MW  
(to -50MW if 1.5GW new solar, -20MW if 1GW new solar)



# Policy goals

## Harness the flexibility of electrified appliances

- **Simple** scheduling achieves majority of benefit
- **Feasible now**: control loads, tariffs, incentives
- Dynamic approaches nice to have

## Invest in reducing air-conditioning demand

- Inflexible peaks in underlying demand will drive large costs
- **Feasible now**: insulation & efficiency





Australian  
National  
University

## The opportunities to flex water heating and electric vehicle charging loads in the ACT

April 2025

Dr Bjorn Sturmborg  
[bjorn.sturmborg@anu.edu.au](mailto:bjorn.sturmborg@anu.edu.au)

A/Prof. Marnie Shaw  
[marnie.shaw@anu.edu.au](mailto:marnie.shaw@anu.edu.au)

Dr Bin Lu  
[bin.lu@anu.edu.au](mailto:bin.lu@anu.edu.au)

School of Engineering  
The Australian National University  
Canberra ACT 2600 Australia  
[www.anu.edu.au](http://www.anu.edu.au)

CRICOS Provider No. 00120C

ANU College of Systems and Society

# Thanks

Bjorn Sturmborg  
[bjorn.sturmborg@anu.edu.au](mailto:bjorn.sturmborg@anu.edu.au)


[bjornsturmborg.com.au/electricity/](http://bjornsturmborg.com.au/electricity/)  
for a recording of this presentation



# Minimum demand is less extreme


- Minimum demand continues to **occur in summer**
- **Coincident, non-dynamic EV charging**

(Gunghalin: Low Solar, Low Home EV)



# Minimum demand is less extreme

- High Solar scenario emphasises solar impact over EV impact



(Gunghalin: **High Solar, Low Home EV**)

# Our research

How much electrification *could*\* fit into spare zone substation capacity?

## Inputs & assumptions

### **ACT in 2045:**

- 100% private electric vehicles,
- 100% electric hot water,
- 42% population growth
- **Excl. space heating (inflexible) & industrial (unknown)**
  
- 4 scenarios: solar uptake, EV charging locations (home/away)

# 4 scenarios

We consider two values for rooftop solar additions:

1. a **High solar** scenario, and
2. a **Low solar**.

The values for these are discussed in the ACT rooftop solar by 2045 subsection below. Similarly, we consider two values for EV charging:

1. a **High home charging** scenario, and
2. a **Low home charging** scenario.

The values for the **High home charging** scenario are the Step Change scenario in AEMO's 2024 ESOO (which in turn come from the CSIRO 2023 EV forecast). In the **Low home charging** scenario, 20% of charging is shifted from homes to work/public charging, which doubles the prevalence of work/public charging.


Table 1: Defining variables of solar and EV charging scenarios

<b>Solar scenarios</b>	<b>High solar</b>	<b>Low solar</b>
Rooftop solar additions by 2045	1500 MW	1000 MW
<b>EV charging scenarios</b>	<b>High home charging</b>	<b>Low home charging</b>
Home charging (L1, L2)	68%	48%
Work/public charging (L2)	20%	40%
Public fast charging (L3)	12%	12%




# Demand growth

- 4 scenarios



# Demand growth

- EV add ~45% to demand!
- Heat pump efficiency counterbalances electrification
- Charging EVs away from home reduces substation demand
- High rooftop solar reduces substation demand



# Comparison to evoenergy modelling

## Marsden Jacobs for evoenergy

ACT peak from 650 MW to 1600MW = **150% increase**

## ANU modelling

Zone substation peak demand from 133MW to 175MW = 32% increase


10% PoE from 107MW to 154MW = **44% increase\***

\*only electrifying water heating & private vehicles, excl space heating




# Modelled demand scheduling

- Empirically schedules to fit average low demand times
- Creates **flattish demand profile on average**, but isn't responsive to specific circumstances



# Not projected; what's plausible & preferable



Ref: Joseph Voros, <https://thevoroscope.com/2017/02/24/the-futures-cone-use-and-history/>

